

Attestation

Italian CAM

On the 18th of February 2022, Eurofins Product Testing A/S received a sample of a mineral wool insulation with the product name:

Gyproc Habito Clima Activ'Air® 13+100

supplied by

Saint-Gobain Italia Spa

The emissions were tested according to the Italian CAM Decree DM 23 Giugno 2022 n. 254, GURI n. 183 del 6 agosto 2022. Sampling, testing and evaluation were performed according to ISO 16000-3, ISO 16000-6, ISO 16000-9, ISO 16000-11 (see the test report no. 392-2022-00078001_A_EN).

Evaluation of the emission test result according to Italian CAM:

- The relevant CMR compounds were not detectable after 28 days.
 - The sum of VOC ("TVOC") after 28 days was below the limit of 1500 µg/m³.
 - Formaldehyde after 28 days was below the limit of 60 µg/m³.
 - All other parameters were below their respective limit values after 28 days.
-

4 October 2023



Laura Hartung Sørensen
Analytical Service Manager