

F TECH 003 CERTIFICATE OF CONFORMITY GYPREX®



N° 19 01 001 – PLACO Saint-Gobain – GYPREX® / 1 Ver.0

Given by : CERA-LABO
ZAC DE TESAN
IMPASSE DES CARIGNANS 10
30126 SAINT LAURENT DES ARBRES - France

to : **PLACO SAINT-GOBAIN**
PRÍNCIPE DE VERGARA 132 PLANTA 3
28002 MADRID - SPAIN

Report : **19 01 001 – PLACO Saint-Gobain – GYPREX® / 1 Ver.0** written the 05th February 2019

Conclusions :

The GYPREX® gives the following results:

- The particle class in normal condition face and back is ISO 4 according to the norm ISO 14644-1 : 2015.
- The particle class under vibrations face and back is ISO 4 according to the norm ISO 14644-1 : 2015
- The particle class with a damaged face is ISO 4 according to the norm ISO 14644-1 : 2015

GENERAL CONCLUSIONS


Classification of tiles

The tiles GYPREX® can be used in room of area 4 according to the norm NFS 90-351 : 2013.

Tests	Norms	Acceptance criteria	Conformity
Particle cleanliness class in normal condition face	ISO 14644-1	ISO 4	Conform
Particle cleanliness class in normal condition back	ISO 14644-1	ISO 4	Conform
Particle cleanliness class under vibrations face	ISO 14644-1	ISO 4	Conform
Particle cleanliness class under vibrations back	ISO 14644-1	ISO 4	Conform
Particle cleanliness class with damaged face	ISO 14644-1	ISO 4	Conform

Remarks

- 19 01 001 – PLACO Saint-Gobain – GYPREX® / 1 Ver.0 written the 05th February 2019.


The Director