

## F TECH 003 CERTIFICATE OF CONFORMITY

**GyQuadro Activ'Air®**

**N° 18 04 024 – GYPROC Saint-Gobain – GyQuadro Activ'Air® / 1 Ver.0**



**Given by** : CERA-LABO  
ZAC DE TESAN  
IMPASSE DES CARIGNANS 10  
30126 SAINT LAURENT DES ARBRES - France

**to** : **GYPROC SAINT-GOBAIN PPC ITALIA S.P.A**  
**VIA ETTORE ROMAGNOLI,6**  
**20146 MILANO - ITALIA**

**Report :** **18 04 024 – GYPROC Saint-Gobain – GyQuadro Activ'Air® / 1 Ver.0** written the 13<sup>th</sup> September 2018

### **Conclusions :**

The tile GyQuadro Activ'Air® gives the following results:

- The particle class in normal condition face and back is ISO 4 according to the norm ISO 14644-1 : 2015.
- The particle class under vibrations face and back is ISO 4 according to the norm ISO 14644-1 : 2015
- The particle class with a damaged face is ISO 4 according to the norm ISO 14644-1 : 2015

## GENERAL CONCLUSIONS

### Classification of tiles

The tiles GyQuadro Activ'Air® can be used in room of area 4 according to the norm NFS 90-351 : 2013.

Tests	Norms	Acceptance criteria	Conformity
Particle cleanliness class in normal condition face	ISO 14644-1	ISO 4	Conform
Particle cleanliness class in normal condition back	ISO 14644-1	ISO 4	Conform
Particle cleanliness class under vibrations face	ISO 14644-1	ISO 4	Conform
Particle cleanliness class under vibrations back	ISO 14644-1	ISO 4	Conform
Particle cleanliness class with damaged face	ISO 14644-1	ISO 4	Conform
Particulate removal kinetic	NF S 90-351	CP(0,5) 5	Conform

### Remarks

- The completed results are in report : **18 04 024 – GYPROC Saint-Gobain – GyQuadro Activ'Air® / 1 Ver.0** written the 13<sup>th</sup> September 2018.

The Director

